

SEP 1 1981

JUN 26 1981

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman **NOV 12 1981**
 2. LOCATION NE of SE Section 26 Township 9N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING **NOV 12 1981**
 OR - Grid or Street No. Street or Road Name ADDRESS Rt 1 Box 136 (Morovits)
 AND - If available subdivision name, lot & block No. POST OFFICE Eastman Wi ZIP CODE 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Holding Tank Sewage Absorption Unit: Seepage Pit 70' Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen 80' Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit 80' Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Farm Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	53	6	53	420	clay	Surface	8
						sand rock	8	42
						lime rock	42	275
						sand rock	275	380
						lime rock	380	420

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	new black steel	PE 18.97	Surface	53
	A-53			
	Valley steel			
	Pitless adaptor			

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	53

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 6-8 1981

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 12 inches above below final grade

Depth from surface to normal water level 360 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 370 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-25 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller Business Name and Complete Mailing Address Rt 4 Box 75 Boscobel Wi 53805

133