

SEP 13 1984

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Wuzeka CR-196-G

2. LOCATION SE, SE 1/4, SW 1/4 Section 8 Township 7N Range 4W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Village of Wuzeka

OR - Grid or Street No. Street or Road Name ADDRESS Mills Street

AND - If available subdivision name, lot & block No. POST OFFICE Wuzeka WI ZIP CODE 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>None</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer Sewer	Sewage Sump Clearwater Sump	Clearwater Sump	Septic Tank	Holding Tank	Seepage Pit Seepage Bed Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	<u>Well No. 4</u>

5. Well is intended to supply water for: Village

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>17 1/2</u>	<u>Surface</u>	<u>116</u>	<u>8</u>	<u>198</u>	<u>240</u>	<u>Sand + Gravel + Clay</u>	<u>Surface</u>	<u>44</u>
<u>12</u>	<u>116</u>	<u>198</u>				<u>Mag Limestone</u>	<u>44</u>	<u>75</u>
						<u>Mud Crasse</u>	<u>75</u>	<u>95</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Mfg. & Method of Assembly	From (ft.)	To (ft.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>12</u>	<u>Steel</u>	<u>Surface</u>	<u>116</u>	<u>Shale</u>	<u>95</u>	<u>181</u>
<u>8</u>	<u>Steel</u>	<u>+4</u>	<u>198</u>	<u>Sandstone</u>	<u>181</u>	<u>240</u>

(Note) 12" pipe installed to stop casing formation from 75 to 95

Ralph Faherty reports in a letter received 2/20/85 that the casing is actually 28.55 lb/ft.

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement Grout 12" x 11 1/2"</u>	<u>Surface</u>	<u>116</u>
<u>Cement Grout 8" x 12"</u>	<u>+4</u>	<u>198</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 8/24 1984

11. MISCELLANEOUS DATA

Yield Test: 24 Hrs. at 100 GPM Well is terminated 48 inches  above final grade  below

Depth from surface to normal water level 8 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 46 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to State Lab sp. cap = 2.6 gpm/ft laboratory on 8/24 1984

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph Faherty Business Name and Complete Mailing Address Faherty Drilling Co Platteville WI 53818

CC# WCD 565  
WELL LOG BOOK  
Registered Well Driller