

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
 Form 3300-15
 Rev. 2-79

NOV 23 1981

JAN 1 1982

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Clayton</u>	
2. LOCATION 1/4 Section or Gov't. Lot <u>NW of SW 16</u> Section <u>16</u> Township <u>10N</u> Range <u>3W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Stanley Peterson</u>		ADDRESS	
OR - Grid or Street No. _____ Street or Road Name _____		AND - If available subdivision name, lot & block No. _____		POST OFFICE <u>Soldiers Grove Wis</u> ZIP CODE <u>54655</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>25'</u>		Building Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	
Sewage Sump C.I. Other		Clearwater Sump		Sewage Sump C.I. Other	
Clearwater Dr.		Sewage Sump		Clearwater Sump	
Privy Pet Waste Pit		Pit: Nonconforming Existing well Pump Tank		Subsurface Pumproom Nonconforming Existing	
Barn Gutter		Animal Barn Pen		Animal Yard <u>75'</u>	
Silo With Pit		Glass Lined Storage Facility		Silo w/o Pit	
Earthen Silage Storage Trench Or Pit		Earthen Manure Basin		Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench <u>70'</u>	
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe	
Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls	
Other (Describe)					
5. Well is intended to supply water for: <u>Farm</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
<u>10</u> <u>Surface</u> <u>260</u> <u>6</u> <u>260</u> <u>320</u>			<u>clay</u> <u>Surface</u> <u>0</u> <u>8</u>		
			<u>Sand Rock</u> <u>8</u> <u>80</u>		
			<u>Lime Rock</u> <u>80</u> <u>140</u>		
			<u>Sand Rock</u> <u>140</u> <u>245</u>		
			<u>Shale</u> <u>245</u> <u>320</u>		
7. CASING, LINER, CURBING AND SCREEN			10. TYPE OF DRILLING MACHINE USED		
Material, Weight, Specification			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
Dia. (in.) Mfg. & Method of Assembly			From (ft.) To (ft.)		
<u>6</u> <u>new black steel</u> <u>PE 18.97</u> <u>Surface</u> <u>0</u> <u>260</u>			Well construction completed on <u>Oct 26</u> 19 <u>81</u>		
<u>A-53</u>			Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
<u>Valley steel</u>			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
<u>Pitless adaptor</u>			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
8. GROUT OR OTHER SEALING MATERIAL			Water sample sent to <u>Madison</u> laboratory on <u>Nov. 10</u> 19 <u>81</u>		
Kind From (ft.) To (ft.)			Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.		
<u>clay</u> <u>Surface</u> <u>0</u> <u>8</u>			Signature <u>140</u> <u>Ronald C. Kirschbaum</u> Registered Well Driller		
<u>cement</u> <u>8</u> <u>260</u>			Business Name and Complete Mailing Address <u>Dons Well Drilling Baseobel wis 53805</u>		
11. MISCELLANEOUS DATA					
Yield Test: <u>3</u> Hrs. at <u>7</u> GPM					
Depth from surface to normal water level <u>250</u> Ft.					
Depth of water level when pumping <u>255</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					