

OCT 21 1984

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Clayton Name

2. LOCATION NW Section 29 Township 10N Range 3W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Rita Bane

OR - Grid or Street No. Street or Road Name ADDRESS Route 2

AND - If available subdivision name, lot & block No. POST OFFICE Gay Mills, WI ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Clearwater Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/ Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Country Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	Surface	181			
6"	181	300			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
loose dirt	Surface	10
sand rock	10	167
shale	167	300

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	new black steel plain end A-53 18.97	Surface	181

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on 10-18 1984

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
cement	7 Surface	181
pitless adaptor	0	7

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 6 GPM Well is terminated 10 inches  above final grade  below

Depth from surface to normal water level 210 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 220 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 10-24 1984

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copson Registered Well Driller Business Name and Complete Mailing Address Copson Well Drilling  
Barabool, WI 53805