

State of Wisconsin  
Department of Natural Resources  
Private Water Supply  
Box 7921  
Madison, Wisconsin 53707

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15 Rev. 3-87

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Wauzeka</u>									
2. LOCATION OR - Grid or Street No. <u>SW 14 SE 14</u> Street or Road Name <u>4W</u>		Section <u>8</u>	Township <u>7N</u>	Range <u>7W</u>	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE								
AND - If available subdivision name, lot & block No.		ADDRESS <u>Box 302</u>		POST OFFICE <u>Wauzeka Wis.</u> ZIP CODE <u>53826</u>									
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>25'</u>		Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer						
		C.I.	Other	C.I.	Other	C.I.	Other						
Street Sewer	Other Sewers	Foundation Drain Connected to:		Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank				
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Clearwater Sump		Seepage Pit	Seepage Bed <u>240'</u>				
Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin		Other (Describe)				
							Concrete Floor Only						
							Concrete Floor and Partial Concrete Walls						
5. Well is intended to supply water for: <u>Private</u>						9. FORMATIONS							
6. DRILLHOLE						Kind							
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)								
<u>10</u>	<u>Surface</u>	<u>53</u>				<u>Dirt + loose rock</u>							
<u>6</u>	<u>53</u>	<u>120</u>				<u>Soft shale</u>							
						<u>Hard shale</u>							
7. CASING, LINER, CURBING AND SCREEN													
Dia. (in.)	Material, Weight, Specification		From (ft.)	To (ft.)									
<u>6</u>	<u>New Black Steel</u>		<u>Surface</u>	<u>53</u>									
	<u>Plain End</u>												
	<u>CAC BTM-A53</u>												
	<u>6x21 18.97</u>												
8. GROUT OR OTHER SEALING MATERIAL						10. TYPE OF DRILLING MACHINE USED							
Kind		From (ft.)	To (ft.)										
<u>Griless Adaptor</u>		<u>Surface</u>	<u>7</u>		<input type="checkbox"/> Cable Tool								
<u>Cement</u>		<u>7</u>	<u>53</u>		<input type="checkbox"/> Rotary-air w/drilling mud								
					<input checked="" type="checkbox"/> Rotary-hammer w/drilling mud & air								
					<input type="checkbox"/> Rotary-w/drilling mud								
					<input type="checkbox"/> Reverse Rotary								
					<input type="checkbox"/> Jetting with								
					<input type="checkbox"/> Air								
					<input type="checkbox"/> Water								
11. MISCELLANEOUS DATA						Well construction completed on <u>11-17 1987</u>							
Yield Test: <u>2</u> Hrs. at <u>7</u> GPM		Well is terminated <u>10</u> inches		<input checked="" type="checkbox"/> above final grade		<input type="checkbox"/> below							
Depth from surface to normal water level <u>64</u> Ft.		Well disinfected upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No									
Depth of water level when pumping <u>82</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No									
Water sample sent to <u>MADISO</u> laboratory on <u>12-2 1987</u>													
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.													
Signature <u>Michael D. Binion</u> Registered Well Driller						Business Name and Complete Mailing Address <u>CORIAN WELL DRILLING</u> <u>Bascoe 1, WI. 53805</u>							