

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Utica 10N APR 13 1981

2. LOCATION SW Section 5 Township 10N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Bruce J. Ristow

OR - Grid or Street No. Street Name ADDRESS 1707 Stoughton st.

AND - If available subdivision name, lot & block No. POST OFFICE Tomah, WI

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other 30' Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Clearwater Sump Clearwater Sump Holding Tank Septic Tank 80' Sewage Absorption Unit 100' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	0 Surface	58	6	58	110	clay & base limestone	0 Surface	15
						soft shale	15	40
						hard shale	40	110

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly Dia. (in.) From (ft.) To (ft.)

6 P.E.A-53 18.97 #/ft pitless adapter 0 Surface 58

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)

clay 0 Surface 8

cement 8 58

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 3-2 19 81

11. MISCELLANEOUS DATA Yield Test: 2 Hrs. at 8 GPM Well is terminated 12 inches above below final grade

Depth from surface to normal water level 40 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 45 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 4-6 19 81

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phil Coplan Registered Well Driller Complete Mail Address 308 E. Bluff Rosobel, WI 53805