

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Clayton</u>	
2. LOCATION <u>SW 14 SE 14</u>		Section <u>12</u>	Township <u>10N</u>	Range <u>4W</u>	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Charles Bown</u>
OR - Grid or Street No. _____ Street or Road Name _____		ADDRESS <u>R.R. 1 Box 208</u>		POST OFFICE <u>Soldiers Grove Wis.</u> ZIP CODE <u>54655</u>	
AND - If available subdivision name, lot & block No. _____		4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>8'</u>	
Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:	
C.I.    Other		C.I.    Other		C.I. Sewer    Other Sewer	
Street Sewer		Foundation Drain Connected to:		Sewage Absorption Unit	
San.    Storm    C.I.    Other		Sewer    Sewage Sump    Clearwater Dr.    Clearwater Sump		C.I.    Other    Clearwater Sump    Septic Tank    Holding Tank	
Privy    Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom	
Well    Pump    Tank		Nonconforming Existing		Barn Gutter    Animal Barn Pen    Animal Yard    Silo With Pit	
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe	
Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin	
Concrete Floor Only		Concrete Floor and Partial Concrete Walls		Other: (Describe)	
5. Well is intended to supply water for: <u>Private</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.)    From (ft.)    To (ft.)			From (ft.)    To (ft.)		
<u>10</u> <u>Surface</u> <u>74</u>			<u>loose sand</u> <u>Surface</u> <u>31</u>		
<u>6</u> <u>74</u> <u>100</u>			<u>mud &amp; gravel</u> <u>31</u> <u>66</u>		
			<u>shale</u> <u>66</u> <u>100</u>		
7. CASING, LINER, CURBING AND SCREEN			10. TYPE OF DRILLING MACHINE USED		
Dia. (in.)    Material, Weight, Specification			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
Mfg. & Method of Assembly			<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
<u>6</u> <u>New Blacksteel</u>			<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
<u>Plain End</u>			Well construction completed on <u>11-19</u> 19 <u>86</u>		
<u>CACASTM A-120</u>			Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
<u>#18.97 .280W</u>			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
8. GROUT OR OTHER SEALING MATERIAL			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Kind			Water sample sent to <u>MADISON</u> laboratory on <u>12-9</u> 19 <u>86</u>		
From (ft.)    To (ft.)			Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.		
<u>Slurry</u> <u>Surface</u> <u>7'</u>			Signature <u>Michael D. Bown</u> Registered Well Driller		
<u>Cement</u> <u>7'</u> <u>74'</u>			Business Name and Complete Mailing Address <u>CORPIAN Well Drilling Inc.</u>		
11. MISCELLANEOUS DATA			<u>R.R. 2 Boscobel Wis 53805</u>		
Yield Test: <u>3</u> Hrs. at <u>7</u> GPM					
Depth from surface to normal water level <u>54</u> Ft.					
Depth of water level when pumping <u>63</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					