

JUL 1 1982

AUG 18 1982

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton (SW part)

2. LOCATION NE of SW Section 22 Township 10N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE George Brockway

OR - Grid or Street No. Street or Road Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE ZIP CODE Southwest Pt Says Mills W. 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>12'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other	Clearwater Sump			Seepage Pit Seepage Bed Seepage Trench	
							<u>70'</u>	<u>80'</u>

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>60</u>	<u>10</u>	<u>0</u>	<u>60</u>	<u>Sand</u>	<u>0</u> Surface	<u>50</u>
						<u>Sand + Gravel</u>	<u>50</u>	<u>60</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel PE 18.97</u>	<u>0</u> Surface	<u>60</u>
	<u>A-53 Galley Steel</u>		
	<u>Pitless adapter</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>cement</u>	<u>8</u>	<u>60</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 4-2 1982

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 12 inches above below final grade

Depth from surface to normal water level 35 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 37 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-15 1982

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Krichbaum Registered Well Driller Business Name and Complete Mailing Address Rt 4 Box 75
Dona Well Drilling, Rosabel WI 53805