

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION NE 1/4 SW 1/4 Section 24 Township 10N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Bill Meyers

OR - Grid or Street No. Street or Road Name ADDRESS R.R. 2 Box 233

AND - If available subdivision name, lot & block No. POST OFFICE Gay Mills WI ZIP CODE 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) 40'

Building	Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer	Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other			Seepage Pit	<u>290</u>	
				Clearwater Dr.	Clearwater Sump					Seepage Bed		

Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well		Nonconforming Existing									
		Pump											

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only	
					Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: Private

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>295</u>			
<u>6</u>	<u>295</u>	<u>500</u>			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>New Black Steel</u>	<u>Surface</u>	<u>295</u>
	<u>Plain End</u>		
	<u>KHC</u>		
	<u>#18.97 6x21</u>		
	<u>280W</u>		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay + loose rock</u>	<u>Surface</u>	<u>16</u>
<u>Lime rock + crev.</u>	<u>16</u>	<u>187</u>
<u>Sand rock</u>	<u>187</u>	<u>284</u>
<u>Shale</u>	<u>284</u>	<u>455</u>
<u>White sand rock</u>	<u>455</u>	<u>500</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Bury Tank</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>295</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drifting mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well construction completed on 7-9 1986

Well is terminated 10 inches above final grade below

Depth from surface to normal water level 362 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 407 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to MADISON laboratory on 7-29 1986

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 158 Michael D. Benler Registered Well Driller Business Name and Complete Mailing Address CORPIAN Well Drilling Inc. R.R. 2 Boscobel WI. 53805