

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

MAR 25 1981

WCD

1. COUNTY **Crawford** CHECK (✓) ONE:  Town  Village  City Name **Wauzeka**

2. LOCATION 1/4 Section **NE** Section **18** Township **7N** Range **4W** 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE **Roger Geisler**

OR - Grid or Street No. Street Name **per map from MSA** ADDRESS **Wauzeka, Wis 53826**

AND - If available subdivision name, lot & block No. POST OFFICE

4. Distance in feet from well to nearest: (Record answer in appropriate block) **15**

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other						Seepage Pit
				Clearwater Dr.	Clearwater Sump							Seepage Bed	<b>504</b>
												Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
-------	---------------	-----------------------------	---------------------	-------------	-----------------	-------------	---------------	------------------------------	--------------	--------------------------------------

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
------------------------	-------------------------------	--------------------------------	---------------------------------	---	--------------------------

5. Well is intended to supply water for: **Dwelling**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<b>10</b>	<b>Surface</b>	<b>40</b>	<b>6</b>	<b>40</b>	<b>80</b>	<b>Topsoil</b>	<b>Surface</b>	<b>1</b>
						<b>Sand</b>	<b>1</b>	<b>10</b>
						<b>Sandstone</b>	<b>10</b>	<b>80</b>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<b>6</b>	<b>Sced 40 18:97P.E.</b>	<b>Surface</b>	<b>40</b>
	<b>Pitless</b>		
	<b>Astm-A-53</b>		
	<b>American Steel</b>		

4/15/81 spoke to Mrs Herbeck about the need for clay or bentonite as grouting material

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<b>Backfill w/ Native Soil</b>	<b>Surface</b>	<b>8</b>
<b>Cement grout</b>	<b>8</b>	<b>40</b>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on **Feb 23, 1981**

11. MISCELLANEOUS DATA

Yield Test: **5** Hrs. at **8** GPM Well is terminated **10** inches  above final grade  below

Depth from surface to normal water level **21** Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping **25** Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to **State** laboratory on **Feb 23, 1981**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **Albin Herbeck #482** Complete Mail Address **Box 136 Richland Center, Wis 53581**

Registered Well Driller