

file original  
in Sec. 36  
copy in Sec. 35

NOTE:  
White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

SEP 1 1981

AUG 19 1981 WCD

1. COUNTY <b>Crawford</b>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <b>Clayton</b>	
2. LOCATION		1/2 Section <b>NE</b>	Section <b>36</b>	Township <b>10N</b>	Range <b>4W</b>
OR - Grid or Street No. Street Name		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <b>Rick Schuch</b>			
AND - If available subdivision name, lot & block No.		ADDRESS <b>Rt. 2</b>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		POST OFFICE <b>Gays Mills, Wis 54631</b>			
Building <b>12</b>		Sanitary Bldg. Drain		Sanitary Bldg. Sewer	
Floor Drain Connected To:		C.I. Other		C.I. Other	
Street Sewer		Foundation Drain Connected to:		Sewage Sump	
San. Storm C.I. Other		Sewer Sewage Sump Clearwater Dr.		C.I. Other	
Septic Tank Holding Tank		Sewage Absorption Unit		Sewage Sump	
none		Seepage Pit Seepage Bed Seepage Trench		Clearwater Sump	
Privy Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom	
Well Pump Tank		Nonconforming Existing		Barn Gutter	
Temporary Manure Stack		Watertight Liquid Manure Tank		Animal Barn Pen	
Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Animal Yard	
Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)		Silo With Pit	
5. Well is intended to supply water for: <b>Dwelling</b>		6. DRILLHOLE		9. FORMATIONS	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		Kind From (ft.) To (ft.)		Kind From (ft.) To (ft.)	
10 Surface 40 6 40 115		topsoil Surface 1		Clay 1 3	
7. CASING, LINER, CURBING AND SCREEN		Sandy Clay 3 18		Sandy shale 18 79	
Material, Weight, Specification & Method of Assembly		Sandy shale 18 79		Sandstone 79 115	
Dia. (in.) From (ft.) To (ft.)		6 40 18+97P Surface 40		Astm-A-53	
American steel		8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED	
Kind From (ft.) To (ft.)		Cement grout Surface 40		<input checked="" type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with	
11. MISCELLANEOUS DATA		Yield Test: <b>4</b> Hrs. at <b>9</b> GPM		<input type="checkbox"/> Rotary-air w/drilling mud <input type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air	
Well construction completed on <b>7/14/ 19 81</b>		Well is terminated <b>10</b> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		<input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water	
Depth from surface to normal water level <b>42</b> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping <b>66</b> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Water sample sent to <b>State</b> laboratory on <b>7/14/ 19 81</b>		Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.	
Signature <b>Albin Herbeck #482</b> Registered Well Driller		Complete Mail Address <b>Box 136 Richland Center, Wis 53581</b>			

1169

WGNHS ORIGINAL