

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

RECEIVED-DNR
JUL 16 1987
WATER SUPPLY

WELL CONSTRUCTOR'S REPORT
 Rev. 5-85

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Clayton	
2. LOCATION 1/4 Section or Gov't. Lot ✓ NE		Section 35	Township 10N	Range 4W	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Lorraine Orrick
OR - Grid or Street No. Street or Road Name		ADDRESS Rt 1		POST OFFICE ZIP CODE Gays Mills, Wis 54631	
AND - If available subdivision name, lot & block No.					
4. Distance in feet from well to nearest: (Record answer in appropriate block) 30		Building		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I.		C.I.	
		Other		Other	
		C.I. Sewer		Other Sewer	
		C.I.		C.I.	
		Other		Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm		C.I. Other		Sewage Sump	
				Clearwater Sump	
				Septic Tank	
				Holding Tank	
				Sewage Absorption Unit	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench	
Privy		Pet Waste Pit		Manure Hopper or Retention or Pneumatic Tank	
		Pit: Nonconforming Existing		Sewage Sump	
		Well		Clearwater Sump	
		Pump		Clearwater Dr.	
		Tank			
Subsurface Pumproom		Barn Gutter		Animal Barn Pen	
Nonconforming Existing				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Storage Trench Or Pit	
				Earthen Manure Basin	
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
				Manure Storage Basin	
				Concrete Floor Only	
				Concrete Floor and Partial Concrete Walls	
				Other (Describe)	
5. Well is intended to supply water for: Dwelling				9. FORMATIONS	
				Kind From (ft.) To (ft.)	
6. DRILLHOLE				Topsoil	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)				Surface 1	
10 Surface 40 6 40 90				Clay 1 17	
				Shale 17 79	
7. CASING, LINER, CURBING AND SCREEN				Sandstone 79 90	
Material, Weight, Specification					
Dia. (in.) Mfg. & Method of Assembly From (ft.) To (ft.)					
6 Sced 40 18:97P.E. Surface 40					
Pitless					
Astm A 53B					
6 5/8 W. 280 ERW					
1200 PSI					
V. S. P.					
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED	
Kind From (ft.) To (ft.)				<input checked="" type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with	
Backfill W. native soil Surface 8				<input type="checkbox"/> Rotary-air w/drilling mud <input type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air	
Cement grout 8 40				<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water	
11. MISCELLANEOUS DATA				Well construction completed on June 29, 1987	
Yield Test: 4 Hrs. at 8 GPM				Well is terminated XX above final grade <input type="checkbox"/> below	
Depth from surface to normal water level 40 Ft.				Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping 45 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to State laboratory on 6/29, 1987					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature A. Herbek #482 A. Herbek			Business Name and Complete Mailing Address Box 136 Richland Center, Wis 53581		
Registered Well Driller					