

OCT 25 1985

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION SW 1/4 SE 1/4 Section 6 Township 10N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Evelyn Nein

OR - Grid or Street No. Street or Road Name ADDRESS Rt. 1 Box 99A

AND - If available subdivision name, lot & block No. POST OFFICE Ferrysville, WI ZIP CODE 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected to:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San. Storm Other Sewers: C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit: Seepage Pit Seepage Bed 290' Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin: Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Private

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	261			
6"	261	445			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	New Black Steel Plain End CA Conduven A-53 18.97 w/ft D.T.	Surface	261

9. FORMATIONS

Kind	From (ft.)	To (ft.)
0-10 DIRT	Surface	10
LIMEROCK	10	119
SHALE	119	157
SANDROCK	157	253
SHALE	253	445

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Bury TANK	Surface	7
Cement	7	261

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drifting mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 9-24 19 85

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 10 inches above below final grade

Depth from surface to normal water level 331 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 378 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to MADISON WI laboratory on 10-22 19 85

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Michael D. Benj... Well Driller Business Name and Complete Mailing Address CORPIAN WELL DRILLING R.R. 2 BOX 4 Boscobel WI 53805