

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Utica

2. LOCATION 1/4 Section ~~11~~ Section 27 Township 10 N Range 5 W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Dan Wokosin

OR - Grid or Street No. Street Name ADDRESS R1 Box 13A

AND - If available subdivision name, lot & block No. POST OFFICE Hayes Mills, Wi. 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 10' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 65' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphouse Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home 9. FORMATIONS

6. DRILLHOLE						Kind	From (ft.)	To (ft.)	
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)				
<u>10</u>	<u>Surface</u>	<u>225</u>	<u>6</u>	<u>225</u>	<u>400</u>	<u>Clay & stone</u>	<u>Surface</u>	<u>0</u>	<u>30</u>
						<u>limestone</u>	<u>30</u>	<u>120</u>	
						<u>soft sandstone</u>	<u>120</u>	<u>200</u>	

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly From (ft.) To (ft.)

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel R.E. 18.97 A-53</u>	<u>Surface</u>	<u>225</u>	<u>hard limestone</u>	<u>200</u>	<u>335</u>
	<u>Keystone Pipe</u>			<u>sandstone</u>	<u>335</u>	<u>400</u>
	<u>Bitless adapter</u>					

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)

<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>225</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 5-20-1980

11. MISCELLANEOUS DATA Yield Test: 5 Hrs. at 6 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 300 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 325 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 5-28-1980

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Lopian Registered Well Driller Complete Mail Address Boscobel, Wi. R2 Box 4 53805