

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

JAN 7 1987

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name Freeman	
2. LOCATION OR - Grid or Street No. Street or Road Name AND - If available subdivision name, lot & block No.		1/4 Section or Gov't Lot SW SE	Section 3	Township 10N	Range 6W	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Lawrence Pollock
4. Distance in feet from well to nearest: (Record answer in appropriate block) 50+		Building	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer	Storm Bldg. Drain C.I. Other
Street Sewer San. Storm	Other Sewers C.I. Other	Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Clearwater Sump	Sewage Sump C.I. Other	Clearwater Sump	Septic Tank 25+	Holding Tank
Privy	Pet Waste Pit	Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen	Animal Yard
Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls	Other (Describe)
5. Well is intended to supply water for: Dwelling				9. FORMATIONS		
6. DRILLHOLE				Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	From (ft.) To (ft.)
10	Surface	42	6	42	125	Topsoil Surface 1
						Clay 1 15
						Shale 15 125
7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification						
Dia. (in.)	Mfg. & Method of Assembly	From (ft.)	To (ft.)			
6	Sced #40 18497 P.	E. Surface	42			
	Pitless					
	Astm A 53B					
	6 5/8 O. D. 280 ERW.					
	K H Taiwan					
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED		
Kind		From (ft.)	To (ft.)	<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
Backfill W. native soil		Surface	8	<input type="checkbox"/> Rotary-air w/drilling mud	<input type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
Cement Grout		8	42	<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water
11. MISCELLANEOUS DATA				Well construction completed on Dec 22, 1986		
Yield Test: 6 Hrs. at 8 GRM				Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth from surface to normal water level 77 Ft.				Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping 82 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to _____ State laboratory on Dec 22, 1986						
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.						
Signature Albin Herbeck #482 Registered Well Driller				Business Name and Complete Mailing Address Box 136 Richland Center, Wis 53581		