

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Freeman, James Meives

2. LOCATION NW 1/4 NE 1/4 Section 7 Township 10N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE James Meives

OR - Grid or Street No. Street or Road Name ADDRESS RR

AND - If available subdivision name, lot & block No. POST OFFICE Ferryville, Wi. ZIP CODE 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer			
		C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other		
Street Sewer	Other Sewers	Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank		
San.	Storm	C.I.	Other	Sewer	Sewage Sump				Seepage Pit				
				Clearwater Dr.	Clearwater Sump				Seepage Bed				
									Seepage Trench				
Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well		Nonconforming Existing									
		Pump											
		Tank											
Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)							
					Concrete Floor Only								
					Concrete Floor and Partial Concrete Walls								

5. Well is intended to supply water for: private

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
10	Surface	72				Soft shale	Surface		66'
6	72	120				hard shale		66'	69'
						hard sandrock		69	120'

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	New Plain End Black steel ASTM A-120 CAB #18,97 280W	Surface	72

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	Surface	72

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 2-16 1987

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 7 GPM Well is terminated 12 inches  above final grade  below

Depth from surface to normal water level 51 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 67 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to MADISON laboratory on 2-18 1987

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Michael O. Beinborn Registered Well Driller Business Name and Complete Mailing Address Gorplan Well Drilling Inc RR 2 Boscobel, Wi. 53805