

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Freeman Name

2. LOCATION NW Section 8 Township 10N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street or Road Name ADDRESS Jerryville, WI
 AND - If available subdivision name, lot & block No. POST OFFICE ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15'

San. Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
	C.I. <input checked="" type="checkbox"/> Other <input type="checkbox"/>	Sewer	C.I. <input type="checkbox"/> Other <input type="checkbox"/>	C.I. <input type="checkbox"/> Other <input type="checkbox"/>	C.I. <input type="checkbox"/> Other <input type="checkbox"/>	C.I. <input type="checkbox"/> Other <input type="checkbox"/>	Seepage Pit Seepage Bed Seepage Trench	

5. Well is intended to supply water for: country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	125	6	125	140	clay & loose lime	Surface	13
						soft shale	13	115
						hard sandstone	115	140

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	new black steel	P.E. 18,97	Surface	125
	A-120	Sumpton Pipe		
	tube	pitless adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	125

9. FORMATIONS

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 10-30-81

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 10 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 100 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 125 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 2-23-82

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Philip Caplan Registered Well Driller Business Name and Complete Mailing Address Kenneth Caplan & Sons, Inc
189 Rt. 2 Box 4 - Boscobel, WI 53805