

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

JAN 19 1981

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Wauzeka Name Steve Oswald JAN 27 1981

2. LOCATION NE 9 7N SW 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE

OR - Grid or Street No. Street Name ADDRESS RR 1

AND - If available subdivision name, lot & block No. POST OFFICE Wauzeka, WI

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>12'</u>	C.I. <u>NA</u> Other	C.I. <u>30'</u> Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 100'

San.	Storm	C.I.	Other	Sewer	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
				Clearwater Dr.	Clearwater Sump		<u>50</u>		Seepage Pit
									Seepage Bed
									Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pump Room Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>0</u>	<u>43</u>	<u>6</u>	<u>43</u>	<u>80</u>	<u>Clay</u>		<u>0</u>	<u>30</u>
	<u>Surface</u>					<u>hard sandstone</u>		<u>30</u>	<u>80</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>A-53 18.97/lb</u> <u>new black steel</u> <u>pitless adapter</u>	<u>0</u>	<u>43</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>43</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 12-23 1980

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 8 GPM Well is terminated 24 inches above final grade below

Depth from surface to normal water level 45 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 55 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 1-12 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phil Coplan Registered Well Driller Complete Mail Address 308 E. Bluff
Doscohel, WI 53805