

NOTE:  
 White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Seneca

2. LOCATION SW of SW Section 11 Township 10N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Ron Woods

OR - Grid or Street No. Street or Road Name ADDRESS 10827 S Lloyd Dr

AND - If available subdivision name, lot & block No. POST OFFICE Worth, Ill ZIP CODE 60482

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>15'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to Sewage Sump Clearwater Sump Clearwater Dr. Septic Tank Holding Tank Sewage Absorption Unit Manure Hopper or Retention or Pneumatic Tank

San. Storm C.I. Other Sewer Sewage Sump C.I. Other Clearwater Sump Clearwater Dr. not on Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>262</u>	<u>6</u>	<u>262</u>	<u>400</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel PE 18.97 PSI 1200 A-120 USP pitless adaptor</u>	<u>Surface</u>	<u>262</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>18</u>
<u>lime rock</u>	<u>18</u>	<u>30</u>
<u>clay</u>	<u>30</u>	<u>40</u>
<u>lime rock</u>	<u>40</u>	<u>160</u>
<u>sand rock</u>	<u>160</u>	<u>250</u>
<u>shale</u>	<u>250</u>	<u>400</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>262</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on 4-20 1985

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 12 inches  above final grade  below

Depth from surface to normal water level 355 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 358 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 4-23 1985

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschman Registered Well Driller Business Name and Complete Mailing Address Rt 4 Box 75 Dons Well Drilling Boscobel WI 53805