

JUN 17 1985

1. COUNTY CRAWFORD		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name Freeman									
2. LOCATION 1/4 Section or Gov't. Lot NW 1/4, SE 1/4		Section 11	Township 10N	Range 6W	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Leon Lester									
OR - Grid or Street No.		Street or Road Name			ADDRESS 2416 N. Washtenaw									
AND - If available subdivision name, lot & block No.				POST OFFICE Chicago ILL.		ZIP CODE 60647								
4. Distance in feet from well to nearest: (Record answer in appropriate block)	Building	Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:	Storm Bldg. Drain		Storm Bldg. Sewer					
	40'	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other			
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank		
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	None		Seepage Pit	Seepage Bed None		Seepage Trench	
Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/ Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin	
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin		Other (Describe)				
								Concrete Floor Only						
								Concrete Floor and Partial Concrete Walls						
5. Well is intended to supply water for: Private					9. FORMATIONS									
					Kind			From (ft.)	To (ft.)					
6. DRILLHOLE														
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)									
10"	0 Surface	274				Clay			0 Surface	10				
6"	274	420				Lime Rock & CREVICE			10	178				
						Sand rock			178	264				
						Shale			264	420				
7. CASING, LINER, CURBING AND SCREEN														
Material, Weight, Specification														
Mfg. & Method of Assembly														
Dia. (in.)			From (ft.)	To (ft.)										
6"	Plain End New Black Steel		0 Surface	274										
	R. 97 16/ft.													
	CA CONDUVEN													
8. GROUT OR OTHER SEALING MATERIAL														
Kind		From (ft.)	To (ft.)											
Cement		0 Surface	274											
Pitless Adaptor		0	7											
10. TYPE OF DRILLING MACHINE USED														
<input type="checkbox"/> Cable Tool					<input type="checkbox"/> Rotary-hammer w/drilling mud & air					<input type="checkbox"/> Jetting with				
<input type="checkbox"/> Rotary-air w/drilling mud					<input checked="" type="checkbox"/> Rotary-hammer & air					<input type="checkbox"/> Air				
<input type="checkbox"/> Rotary-w/drilling mud					<input type="checkbox"/> Reverse Rotary					<input type="checkbox"/> Water				
					Well construction completed on 5-10 19 85									
11. MISCELLANEOUS DATA														
Yield Test: 2		Hrs. at 1	GPM	Well is terminated 10 inches			<input checked="" type="checkbox"/> above final grade							
Depth from surface to normal water level 350 Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No												
Depth of water level when pumping 385 Ft.		Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No									
Water sample sent to MADISON laboratory on 6-12 19 85														

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

195 Signature
Kenneth Capron
 Registered Well Driller

Business Name and Complete Mailing Address
COPIAN Well DRILLING
R. R. 2 Boscobel, WI. 53805