

State of Wisconsin  
 Department of Natural Resources  
 Private Water Supply  
 Box 7921  
 Madison, Wisconsin 53707

NOTE:  
 White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
 Form 3300-15 Rev. 5-85

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Lenoir

2. LOCATION SW of SW Section 35 Township 10N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Leonard Dyszelki

OR - Grid or Street No. Street or Road Name ADDRESS 1

AND - If available subdivision name, lot & block No. POST OFFICE Terryville W. ZIP CODE 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block) 30'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San.  Storm  Other Sewers: C.I.  Other  Foundation Drain Connected to: Sewer  Sewage Sump  Clearwater Dr.  Sewage Sump  Clearwater Sump  Sewage Sump  Clearwater Sump

50' 50' Sewage Absorption Unit: Seepage Pit  Seepage Bed  Seepage Trench 60'

Manure Hopper or Retention or Pneumatic Tank  Manure Storage Basin: Concrete Floor Only  Concrete Floor and Partial Concrete Walls  Other (Describe)

5. Well is intended to supply water for: trailer home

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Surface		
clay	0	8
shale	8	100

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	64	6	64	100

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	new black steel PE 1.8.97	Surface	64
	PSI-1200		
	A-120		
	VSP pipe adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
Cement	8	64

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM

Depth from surface to normal water level 68 Ft.

Depth of water level when pumping 70 Ft. Stabilized  Yes  No

Well construction completed on 6-16 1987

Well is terminated 12 inches  above final grade  below

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 6-17 1987

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kueckbaun  
 Registered Well Driller  
 1977

Business Name and Complete Mailing Address 16189 Dutch Hill Rd  
Dons Well Drilling Rosend WI 53805