

AUG 31 1988

State of Wisconsin  
 Department of Natural Resources  
 Private Water Supply - WS/2  
 Box 7921  
 Madison, WI 53707

**First Water Quality Test For WISCONSIN UNIQUE WELL NUMBER AZ 839**

Property Owner Ronald Schmitz Telephone Number \_\_\_\_\_

Mailing Address 1216 Mitchell Ave

City Waterloo State Iowa Zip Code 50702

County Crawford County Well Location Permit No. W Well Completion Date 062788  
MM DD YY

1. Location (Please type or print using a black pen.)  
 Town  City  Village Fire # (if available) \_\_\_\_\_  
 of Seneca  
 Grid or Street Address or Road Name and Number (if available) \_\_\_\_\_

Subdivision Name \_\_\_\_\_ Lot # \_\_\_\_\_ Block # \_\_\_\_\_

Well Constructor (Business Name) Corplan Well Drilling Registration # 75

Address 501 E. Oak

City Boscobel, WI State \_\_\_\_\_ Zip Code 53805

2. Mark well location in correct 40-acre parcel of section.

N  
 W E  
 S

Gov't Lot # \_\_\_\_\_ or SW 1/4 of SE 1/4 of Section 35, T 10 N; R 6  E  W

3. Well Type  New  
 Replacement  Reconstruction/Rehabilitation

of well constructed in 19 \_\_\_\_\_

Reason for new, reconstructed, replaced, or rehabilitated well?  
New Dwelling

Drilled  Driven Point  Jetted  Other \_\_\_\_\_

4. Well serves 1 # of homes and/or \_\_\_\_\_  
 (ex: barn, restaurant, church, school, industry, etc.)

High Capacity Well?  Yes  No  
 High Capacity Property?  Yes  No

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings?  Yes  No

Well Located in Floodplain?  Yes  No \_\_\_\_\_

Distance In Feet From Well To Nearest:

1. Landfill	9. Downspout/Yard Hydrant	17. Wastewater Sump
<u>35</u> 2. Building Overhang	10. Privy	18. Paved Animal Barn Pen
3. Septic or Holding Tank	11. Foundation Drain to Clearwater	19. Animal Yard or Shelter
4. Sewage Absorption Unit	12. Foundation Drain to Sewer	20. Silo - Type _____
5. Nonconforming Pit	13. Building Drain	21. Barn Gutter
6. Buried Home Heating Oil Tank	<input type="checkbox"/> Cast Iron or Plastic <input type="checkbox"/> Other	22. Manure Pipe <input type="checkbox"/> Gravity <input type="checkbox"/> Pressure
7. Buried Petroleum Tank	14. Building Sewer <input type="checkbox"/> Gravity <input type="checkbox"/> Pressure	<input type="checkbox"/> Cast Iron or Plastic <input type="checkbox"/> Other
8. Shoreline/Swimming Pool	<input type="checkbox"/> Cast Iron or Plastic <input type="checkbox"/> Other	23. Other Manure Storage _____
	15. Collector Sewer	Other NR 112 Waste Source _____
	16. Clearwater Sump	24. _____

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
10	0 surface	42
6	42	80

Method of constructing upper enlarged drillhole. (If applicable ✓ more than one.)

1. Rotary - Mud Circulation  
 2. Rotary - Air  
 3. Rotary - Foam  
 4. Reverse Rotary  
 5. Cable-tool Bit 10 in. dia.  
 6. Temp. Outer Casing 10 in. dia.  
 Removed?  Yes  No  
 If no, explain \_\_\_\_\_  
 7. Other \_\_\_\_\_

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
<u>IB</u> <u>bit 5' loose rock</u>	0 surface	5
<u>SH</u> <u>soft shale</u>	5	32
<u>HM</u> <u>hard shale</u>	32	56
<u>N</u> <u>sandrock</u>	56	80

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	<u>New black steel</u>	0 surface	42
	<u>Plain End</u>		
	<u>CAC ASTM A-53A</u>		
	<u>6x21 #18.97</u>		
Dia. (in.)	screen type and material	From	To

10. Static Water Level \_\_\_\_\_ ft. above ground level  
17 ft. below ground surface

11. Pump Test  
 Pumping Level 38 ft. below surface  
 Pumping at 10 GPM for 2 hours

12. Well Is:  
 Above Grade  
 Below Grade  
 Developed?  Yes  No  
 Disinfected?  Yes  No  
 Capped?  Yes  No

8. Grout or Other Sealing Material

Method	Kind of Sealing Material	From (ft.)	To (ft.)	Sacks Cement
<u>Tramex</u>				
	<u>Neat Cement</u>	0 surface	42	16

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?  
 Yes  No If no, explain \_\_\_\_\_

14. Signature of Well Constructor Michael D. Beinton M.D. Date Signed 6-27-88  
 Signature of Drill Rig Operator Michael D. Beinton M.D. Date Signed 6-27-88