

NOTE:  
Blue Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Wauzeka Name NOV 1 1982

2. LOCATION SW Section 14 Township 7N Range 5W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Bob Roth

OR - Grid or Street No. Street or Road Name ADDRESS 1100 Pine E

AND - If available subdivision name, lot & block No. POST OFFICE Glennview, Ill ZIP CODE 60025

4. Distance in feet from well to nearest: (Record answer in appropriate block) 20'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption	Manure Hopper or Retention or Pneumatic Tank
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump				70'	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only	
					Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
10	Surface	218	6	218	340	limestone		Surface	197
						hard sandstone		197	308
						hard shalestone		308	340

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	PE 18.97 <sup>1/2</sup> / <sub>ft</sub>	Surface	218
	A53 Luwington		
	Pipe & Spline		
	Pitless adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	218

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 8-31 1982

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 10 GPM Well is terminated 18 inches  above final grade  below

Depth from surface to normal water level 280 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 290 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 10-28 1982

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phil Caplan Registered Well Driller

Business Name and Complete Mailing Address Kenneth Caplan & Son, Inc  
Rt. 2 Box 4 Basco, WI 53805