

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

MAR 17 1986

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION SE of SE Section 29 Township 11N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE WM Boettcher

OR - Grid or Street No. Street or Road Name R3W ADDRESS 521 East Liffallen

AND - If available subdivision name, lot & block No. POST OFFICE Tempe ZIP CODE Arg 85282

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To	Storm Bldg. Drain	Storm Bldg. Sewer
<u>15'</u>	C.I. Other	C.I. Other	C.I. Sewer Other	C.I. Other	C.I. Other
Street Sewer	Other Sewers	Foundation Drain Connected to	Sewage Sump	Clearwater Sump	Septic Tank
San. Storm	C.I. Other	Sewer	C.I. Other	Clearwater Sump	Septic Tank
		Clearwater Dr.			
Privy	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard
Pet Waste Pit	Well Pump Tank	Nonconforming Existing			
Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin
					Concrete Floor Only Concrete Floor and Partial Concrete Walls
					Other (Describe)

5. Well is intended to supply water for: farm home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>42</u>	<u>6</u>	<u>42</u>	<u>120</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel PE 18197</u>	<u>Surface</u>	<u>42</u>
	<u>PSI 1200</u>		
	<u>A-120</u>		
	<u>USP adaptor</u>		
	<u>Pittman adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>42</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>12</u>
<u>shale rock</u>	<u>12</u>	<u>120</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 11-4 1985

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 80 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 78 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 11-18 1985

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald Kuschbauer Registered Well Driller Business Name and Complete Mailing Address Boettcher Well Drilling
114 Box 75 Brookfield Wis 53805