

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

JAN 19 1981

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Clayton</u>	
2. LOCATION OR - Grid or Street No. <u>NE 29</u> Street Name <u>11N 3W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING <u>Daniel Everson</u>		DATE <u>JAN 27 1981</u> CHECK (✓) ONE	
AND - If available subdivision name, lot & block No.		ADDRESS <u>Rt. 2</u> POST OFFICE <u>Soldiers Grove</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other <u>50'</u>	
		Floor Drain Connected To: C.I. Sewer Other Sewer		Storm Bldg. Drain C.I. Other	
		Storm Bldg. Sewer C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Clearwater Sump	
		Sewage Sump C.I. Other		Clearwater Sump	
Privy		Pet Waste Pit		Septic Tank <u>50'</u> Holding Tank	
Pit: Nonconforming Existing		Subsurface Pumproom Nonconforming Existing		Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench <u>75'</u>	
Well Pump Tank		Barn Gutter <u>150'</u>		Animal Barn Pen	
Animal Yard		Silo With Pit		Glass Lined Storage Facility	
Silo w/o Pit		Earthen Silage Storage Trench Or Pit			
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)	
5. Well is intended to supply water for: <u>Country Home</u>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		<u>Clay</u>		<u>0</u> <u>7</u>	
<u>10</u> <u>Surface</u> <u>40</u> <u>6</u> <u>40</u> <u>80</u>		<u>Shale (hard)</u>		<u>7</u> <u>50</u>	
		<u>hard sandstone</u>		<u>50</u> <u>80</u>	
7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)			
Dia. (in.)		<u>6</u> <u>Surface</u> <u>40</u>			
<u>P.E.A-53</u>					
<u>18.75/lb. new</u>					
<u>black steel</u>					
<u>fitless adapter</u>					
8. GROUT OR OTHER SEALING MATERIAL		Kind		From (ft.) To (ft.)	
		<u>Clay</u>		<u>0</u> <u>7</u>	
		<u>Cement</u>		<u>7</u> <u>40</u>	
10. TYPE OF DRILLING MACHINE USED		Cable Tool <input type="checkbox"/>		Rotary-hammer w/drilling mud & air <input type="checkbox"/>	
		Rotary-air w/drilling mud <input type="checkbox"/>		<input checked="" type="checkbox"/> Rotary-hammer & air	
		Rotary-w/drilling mud <input type="checkbox"/>		Reverse Rotary <input type="checkbox"/>	
				Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	
11. MISCELLANEOUS DATA		Yield Test: <u>3</u> Hrs. at <u>8</u> GPM		Well construction completed on <u>12-26</u> 19 <u>80</u>	
Depth from surface to normal water level <u>30</u> Ft.		Well is terminated <u>15</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth of water level when pumping <u>40</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <u>Madison</u> laboratory on <u>1-14</u> 19 <u>81</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Phil Caplan</u> Registered Well Driller		Complete Mail Address <u>308 E. Bluff</u> <u>Roscabel, WI 53805</u>			