

AUG 12 1980

1. COUNTY <b>Crawford</b>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <b>Claton</b>	
2. LOCATION 1/4 Section <b>SW</b> Section <b>32</b> Township <b>11N</b> Range <b>3W</b>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <b>Harlan Langmire</b>			
OR - Grid or Street No. Street Name		ADDRESS <b>Rt. 1</b>			
AND - If available subdivision name, lot & block No.		POST OFFICE <b>Soldiers Grove, Wis 54655</b>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <b>40</b>	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Clearwater Dr.	Sewage Sump C.I. Other
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumphouse Nonconforming Existing	Barn Gutter Animal Barn Pen Animal Yard Silo w/o Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank
				Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
5. Well is intended to supply water for: <b>Dwelling</b>			9. FORMATION		
6. DRILLHOLE			Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<b>10</b>	<b>Surface</b>	<b>42</b>	<b>6</b>	<b>42</b>	<b>100</b>
					<b>Clay</b>
					<b>Sand &amp; Gravel</b>
					<b>Shale</b>
7. CASING, LINER, CURBING AND SCREEN			From (ft.)		
Material, Weight, Specification & Method of Assembly			To (ft.)		
Dia. (in.)					
<b>6</b>	<b>Specd 40 18:97 P.E.</b>		<b>Surface</b>		<b>42</b>
	<b>Pitless</b>				
	<b>Astm-A-53</b>				
	<b>American Steel</b>				
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind			From (ft.) To (ft.)		
<b>Backfill w/ Native soil</b>			<b>Surface 8</b>		
<b>Cement Grout</b>			<b>8 42</b>		
			Well construction completed on <b>Aug 4, 19 80</b>		
11. MISCELLANEOUS DATA			Well is terminated <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Yield Test: <b>3</b> Hrs. at <b>9</b> GPM			Well is terminated <b>10</b> inches <input type="checkbox"/> below final grade		
Depth from surface to normal water level <b>65</b> Ft.			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <b>70</b> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <b>State</b> laboratory on <b>Aug 4, 19 80</b>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <b>Albin Herbeck #482</b> Registered Well Driller			Complete Mail Address <b>Box 136 Richland Center, Wis 53581</b>		