

NOV 10 1981 WCD

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION NE/SE? Section 34 Township 11N Range 3W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 ADDRESS North Clayton Church
Rt. 2
 POST OFFICE Soldiers Grove, WI ZIP CODE _____

4. Distance in feet from well to nearest: (Record answer in appropriate block) 30'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other				90	Seepage Pit	

Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well	Pump	Nonconforming	Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin		Other (Describe)
					Concrete Floor Only	Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: church

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	165	6	165	340	loose limestone	Surface	29
						limestone & clay	29	150
						hard limestone	150	340

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	P.E. 18.97 $\frac{1}{2}$ "	Surface	165
	A-53 Kent Steel		
	Pitless adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	165

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on 7-8 1981

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 10 GPM Well is terminated 18 inches above final grade below

Depth from surface to normal water level 275 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 280 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 11-3 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 211 [Signature] Registered Well Driller

Business Name and Complete Mailing Address
Kenneth Corpiam & Sons, Inc
Rt. 2 Box 4 Boscobel, WI 53805