

MAY 30 1985

1. COUNTY **CRAWFORD** CHECK (✓) ONE: Town Village City Name **Soldiers Grove** **CLAYTON**

2. LOCATION $\frac{1}{4}$ Section or Gov't. Lot **SW $\frac{1}{4}$, NE $\frac{1}{4}$** Section **35** Township **T11N** Range **3W** 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE **Roy Ray**

OR - Grid or Street No. Street or Road Name **??** ADDRESS **R. R. 2 Box 238A**

AND - If available subdivision name, lot & block No. POST OFFICE **Soldiers Grove** ZIP CODE **WI. 54655**

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building **20'** Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Manure Hopper or Retention or Pneumatic Tank

San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. Clearwater Sump C.I. Other Clearwater Sump **50'** Seepage Pit Seepage Bed **80'** Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pumproom Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: **FARM HOME**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	0 Surface	114'			
6"	114	260			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
# Clay	0 Surface	26
LIME ROCK GREDICE	26	223
SAND ROCK	223	260

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	New Black Steel Plain End	0 Surface	114
	A-53 18.97		
	18.97		
	UNITED STEEL		
	CA CONDUIT		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	7 Surface	114
Pitless Adaptor	0	7

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on **4-26** 19 **85**

11. MISCELLANEOUS DATA

Yield Test: **3** Hrs. at **8** GPM Well is terminated **10** inches above final grade below

Depth from surface to normal water level **190** Ft. Well disinfected upon completion Yes No

Depth of water level when pumping **200** Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to **MADISON** laboratory on **5-2** 19 **85**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **Kenneth Roy Ray** Registered Well Driller Business Name and Complete Mailing Address **CORPIAN WELL DRILLING R. R. 2 Box 4 BOSCOBEL, WI. 53805**