

JUL 21 1981
SEP 1 1981 *wed*

1. COUNTY <i>Crawford</i>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <i>Utica</i>	
2. LOCATION OR - Grid or Street No. Street or Road Name		1/4 Section or Gov't. Lot <i>SW 20 11N 4W</i>			3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <i>Kevin Burke</i>	
AND - If available subdivision name, lot & block No.				ADDRESS <i>RR 4</i>		
				POST OFFICE <i>Uroquois WI</i>		
				ZIP CODE <i>54665</i>		
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <i>40'</i>		Sanitary Bldg. Drain C.I. Other		
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer		
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other		
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump		
				Sewage Sump C.I. Other		
				Clearwater Sump		
				Septic Tank <i>60'</i>		
				Holding Tank		
				Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench		
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing		
				Barn Gutter		
				Animal Barn Pen		
				Animal Yard		
				Silo With Pit		
				Glass Lined Storage Facility		
				Silo w/o Pit		
				Earthen Storage Trench Or Pit		
				Earthen Silage Storage Trench Or Pit		
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe		
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		
				Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls		
				Other (Describe)		
5. Well is intended to supply water for: <i>Country home</i>				9. FORMATIONS		
6. DRILLHOLE				Kind		
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)				From (ft.) To (ft.)		
<i>10 Surface 233 6 233 380</i>				<i>clay Surface 12 219 223 296 380</i>		
				<i>broken limestone</i>		
				<i>white clay</i>		
				<i>hard sandstone</i>		
				<i>hard shalestone</i>		
7. CASING, LINER, CURBING AND SCREEN						
Dia. (in.) Material, Weight, Specification Mfg. & Method of Assembly				From (ft.) To (ft.)		
<i>6 P.E. 18.97 lbs/ft A53 Livingston Pipe & Tube Pitless Adapter</i>				<i>Surface 233</i>		
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED		
Kind From (ft.) To (ft.)				<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
<i>clay Surface 8</i>				<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
<i>Cement 8 233</i>				<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
				Well construction completed on <i>6-2 1981</i>		
11. MISCELLANEOUS DATA				Well is terminated <i>15</i> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Yield Test: <i>2</i> Hrs. at <i>8</i> GPM				Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level <i>320</i> Ft.				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <i>325</i> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						
Water sample sent to <i>Madison</i> laboratory on <i>7-14 1981</i>						
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.						
Signature <i>Phil Caplan</i> 214 Registered Well Driller				Business Name and Complete Mailing Address <i>Kenneth Caplan & Sons, Inc</i> <i>Rt. 2 Box 4 Boscobel, WI 53805</i>		