

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

MAY 26 1987

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Townville **UTICA**

2. LOCATION NE 1/4 SW 1/4 30 11 N 4 W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
 ADDRESS Lee Leach  
P.O. Box 192  
 POST OFFICE Soldiers Grove, WI ZIP CODE 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Manure Hopper or Retention or Pneumatic Tank  
 San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. Clearwater Sump C.I. Other Clearwater Sump 50' Seepage Pit Seepage Bed 100' Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pumproom Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Private

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	52			
	Surface				
6	52	100			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Dirt</u>	0	8
<u>Soft shale</u>	8	42
<u>Hard shale</u>	42	90

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	<u>New Black Steel Plain End CAC ASTM A-120 18-97 6x21</u>	0	52
		Surface	

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Pitless Adaptor</u>	0	7
<u>Cement</u>	7	52

Well construction completed on 5-5 1987

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 7 GPM

Depth from surface to normal water level 50 Ft.

Depth of water level when pumping 61 Ft. Stabilized  Yes  No

Well is terminated 10 inches  above final grade  below

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to MADISON laboratory on 5-13 1987

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Michael D. Benbow Registered Well Driller

Business Name and Complete Mailing Address  
CORPIAN WELL DRILLING  
R.R. 2 Boscobel, WI 53805