

**First Water Quality Test For
WISCONSIN UNIQUE WELL NUMBER A2 398**


State of Wisconsin
Department of Natural Resources
Private Water Supply - WS/2
Box 7921
Madison, WI 53707

DEC 8 1988

Property Owner Albert Wee Telephone Number 608 624-5477
Mailing Address P.R. 1
City Soldiers Grove State WI Zip Code 54659
County Crawford County Well Location Permit No. W Well Completion Date 11/18/88

1. Location (Please type or print using a black pen.)
 Town City Village Fire # (if available)
of Utica
Grid or Street Address or Road Name and Number (if available)
Subdivision Name Lot # Block #

Well Constructor (Business Name) Corpian Well Drilling 75 Registration #
Address 571 E. OAK
City Boscobel State WI Zip Code 53805



Gov't Lot # or SW 1/4 of NE 1/4 of Section 30; T 11 N; R 4 E W

3. Well Type New Replacement Reconstruction/Rehabilitation
of well constructed in 19 ____
Reason for new, reconstructed, replaced, or rehabilitated well?
Springwater
 Drilled Driven Point Jetted Other

4. Well serves 1 # of homes and/or 2 barns (ex: barn, restaurant, church, school, industry, etc.)
High Capacity Well? Yes No
High Capacity Property? Yes No

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings? Yes No
Well Located in Floodplain? Yes No
Distance In Feet From Well To Nearest:
1. Landfill
30' 2. Building Overhang Garage
60' 3. Septic or Holding Tank
155' 4. Sewage Absorption Unit
5. Nonconforming Pit
6. Buried Home Heating Oil Tank
110' 7. Buried Petroleum Tank
8. Shoreline/Swimming Pool
9. Downspout/Yard Hydrant
10. Privy
11. Foundation Drain to Clearwater
12. Foundation Drain to Sewer
13. Building Drain
 Cast Iron or Plastic Other
14. Building Sewer Gravity Pressure
 Cast Iron or Plastic Other
15. Collector Sewer
16. Clearwater Sump
17. Wastewater Sump
18. Paved Animal Barn Pen
19. Animal Yard or Shelter
450' 20. Silo - Type
140' 21. Barn Gutter
22. Manure Pipe Gravity Pressure
 Cast Iron or Plastic Other
230' 23. Other Manure Solid Storage pit cement
Other NR 112 Waste Source
24.

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> surface	<u>63</u>
<u>6</u>	<u>63</u>	<u>100</u>

Method of constructing upper enlarged drillhole. (If applicable - more than one.)
 1. Rotary - Mud Circulation
 2. Rotary - Air
 3. Rotary - Foam
 4. Reverse Rotary
 5. Cable-tool Bit _____ in. dia.
 6. Temp. Outer Casing 10 in. dia. Removed? Yes No
If no, explain _____
 7. Other _____

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
<u>Spit</u>	<u>0</u> surface	<u>1</u>
<u>Soft Shale</u>	<u>1</u>	<u>58</u>
<u>Hard Shale</u>	<u>58</u>	<u>100</u>

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>New Black Steel Plain End A-53A</u>	<u>0</u> surface	<u>63</u>
	<u>ASTM 6x21</u>		
	<u>18-57</u>		
Dia. (in.)	screen type and material	From	To

10. Static Water Level
30 ft. above ground level
30 ft. below ground surface

11. Pump Test
Pumping Level 57 ft. below surface
Pumping at 10 GPM for 7 hours

12. Well Is:
15 in. Above Grade Below
Developed? Yes No
Disinfected? Yes No
Capped? Yes No

8. Grout or Other Sealing Material

Method	Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
<u>Tramel</u>	<u>Neat Cement</u>	<u>0</u> surface	<u>63</u>	<u>12</u>

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?
 Yes No If no, explain _____

14. Signature of Well Constructor Michael D. Beinborn MDB Date Signed 12-7-88
Signature of Drill Rig Operator Michael D. Beinborn MDB Date Signed 12-7-88

Make additional comments on reverse side about geology, etc.