

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

WCD

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Fallman MAY 19 1981

2. LOCATION 1/4 Section SW Section 21 Township 11N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 ADDRESS Joe Tschumper
6210 Laurel St. Rt. 3

AND - If available subdivision name, lot & block No. POST OFFICE La Crosse, WI 54601

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building N/A Sanitary Bldg. Drain C.I. Other N/A Sanitary Bldg. Sewer C.I. Other N/A Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump C.I. Other Sewage Sump Clearwater Sump Clearwater Sump Septic Tank N/A Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench N/A

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country Home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	0 Surface	47	6	47	120	loose limestone	0 Surface	37
						hard shalestone	37	120

7. CASING LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly Dia. (in.) From (ft.) To (ft.)

6	new black steel	0 Surface	47
	P.E. A-53		
	18.99'/ft		
	pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)

clay	0 Surface	8
cement	8	47

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 4-15 19 81

11. MISCELLANEOUS DATA Yield Test: 2 Hrs. at 8 GPM Well is terminated 18 inches above final grade below

Depth from surface to normal water level 80 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 90 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 5-11 19 81

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phillip Coplan Registered Well Driller Complete Mail Address 308 E. Bluff
Bascoel, WI 53805

224