

NOV 3 1983

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <u>Freeman</u>								
2. LOCATION 1/4 Section or Gov't. Lot <u>NW of SE</u> Section <u>31</u> Township <u>11N</u> Range <u>6W</u> OR - Grid or Street No. Street or Road Name		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Daniel Comp</u>		ADDRESS <u>5426 Tomahawk Trail</u> POST OFFICE <u>Fort Wayne In.</u> ZIP CODE									
AND - If available subdivision name, lot & block No.													
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>121</u>		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
				C.I. Other		C.I. Other		C.I. Sewer Other Sewer		C.I. Other		C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank	
San. Storm		C.I. Other		Sewer		Sewage Sump		Clearwater Sump		C.I. Other		Clearwater Sump	
				Clearwater Dr.		Clearwater Sump						Sewage Absorption Unit	
												Seepage Pit	
												Seepage Bed	
												Seepage Trench <u>250'</u>	
Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard	
				Well		Nonconforming Existing				Silo With Pit		Glass Lined Storage Facility	
				Pump								Silo w/o Pit	
				Tank								Earthen Silage Storage Trench Or Pit	
												Earthen Manure Basin	
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin		Other (Describe)	
										Concrete Floor Only			
										Concrete Floor and Partial Concrete Walls			
5. Well is intended to supply water for: <u>Country home</u>						9. FORMATIONS							
						Kind							
						From (ft.)							
						To (ft.)							
6. DRILLHOLE						Surface							
Dia. (in.)		From (ft.)		To (ft.)		Dia. (in.)		From (ft.)		To (ft.)		Surface	
<u>10</u>		<u>0</u>		<u>120</u>		<u>6</u>		<u>120</u>		<u>140</u>		<u>85</u>	
		Surface										<u>140</u>	
7. CASING, LINER, CURBING AND SCREEN													
Material, Weight, Specification													
Dia. (in.)		Mfg. & Method of Assembly		From (ft.)		To (ft.)							
<u>6</u>		<u>new black steel psi 1200</u>		<u>Surface</u>		<u>120</u>							
		<u>A-120</u>											
		<u>Valley Steel</u>											
		<u>fitless adaptor</u>											
		<u>18.97 P.E.</u>											
8. GROUT OR OTHER SEALING MATERIAL						10. TYPE OF DRILLING MACHINE USED							
Kind						<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water							
From (ft.)		To (ft.)											
<u>Surface</u>		<u>8</u>											
<u>8</u>		<u>120</u>											
11. MISCELLANEOUS DATA						Well construction completed on <u>9-2</u> 19 <u>83</u>							
Yield Test: <u>3</u>		Hrs. at <u>7</u>		GPM		Well is terminated <u>12</u> inches		<input checked="" type="checkbox"/> above final grade		<input type="checkbox"/> below			
Depth from surface to normal water level <u>75</u> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No											
Depth of water level when pumping <u>80</u> Ft.		Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No											
Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No													
Water sample sent to <u>Madison</u> laboratory on <u>10-26</u> 19 <u>83</u>													
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.													
Signature <u>227 Donald C. Kirschbaum</u> Registered Well Driller						Business Name and Complete Mailing Address <u>Box 75</u> <u>Done Well Drilling Roswell WI 53805</u>							