

SEP 10 1982

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION SW of SW 1/4 Section of Gov't. Lot 36 Township 11N Range 8W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Water E Luebke

OR - Grid or Street No. Street or Road Name R6W ADDRESS 18345 W Michaels Rd

AND - If available subdivision name, lot & block No. North Central Pt. POST OFFICE New Berlin WI ZIP CODE 53151

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 6' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 62' Manure Hopper or Retention or Pneumatic Tank 80'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>88</u>	<u>6</u>	<u>88</u>	<u>200</u>	<u>clay + rock</u>	<u>Surface</u>	<u>40</u>
						<u>sand rock</u>	<u>40</u>	<u>200</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel</u>	<u>PE 18.97</u>	<u>Surface</u>	<u>88</u>
	<u>A-53</u>	<u>Valley Steel</u>		
	<u>Pitless adapter</u>			

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>cement</u>	<u>8</u>	<u>88</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 7-30 19 82

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 140 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 145 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-2 19 82

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller Business Name and Complete Mailing Address Box 75
Dons Well Drilling Boothel WI 53805