

SPOTCHECK

NOTE:
 White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town of Name Freeman Desota
 Town Village City

2. LOCATION Lot 1 & 2 Block 6 22 11N 7W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
Cheney Addition ADDRESS Lester Flick

AND - If available subdivision name, lot & block No. POST OFFICE Desota Wi ZIP CODE 54624

4. Distance in feet from well to nearest: (Record answer in appropriate block)
 Building 15' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Septic Tank city Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Factory 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	0 Surface	59	6	59	65	Shale	0 Surface	40
						Sand rock	40	65

7. CASING, LINER, CURBING AND SCREEN
 Material, Weight, Specification
 Dia. (in.) Mfg. & Method of Assembly From (ft.) To (ft.)

6	new black steel PE 18.97	0 Surface	5-9
	A-5.3 Valley steel Pitted adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	0 Surface	8
cement	8	59

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water
 Rotary-air w/drilling mud Rotary-hammer & air
 Rotary-w/drilling mud Reverse Rotary

Well construction completed on 5-28 19 82

11. MISCELLANEOUS DATA
 Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches above final grade below
 Depth from surface to normal water level 20 Ft. Well disinfected upon completion Yes No
 Depth of water level when pumping 25 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-7 19 82

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschman Registered Well Driller Business Name and Complete Mailing Address Box 75
Done Well Drilling Boscobel Wis 53805