

JUL 21 1983

1. COUNTY **CRAWFORD** CHECK (✓) ONE: Town Village City Name **WAUZEKA**

2. LOCATION **NW** 1/4 Section or Gov't. Lot Section **15** Township **7N** Range **5W** 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE **GAYLE EARLY**

OR - Grid or Street No. Street or Road Name ADDRESS **226 STEWART AVE.**

AND - If available subdivision name, lot & block No. POST OFFICE **WAUKEGAN, ILL.** ZIP CODE **60085**

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
NONE	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm C.I. Other	Sewer Clearwater Dr.	Sewage Sump Clearwater Sump	C.I. Other		NONE		Seepage Pit Seepage Bed Seepage Trench	NONE

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: **CAMPER - HAND PUMP**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	Surface	87'			
6"	87'	100'			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
DIRT & LOOSE ROCK	Surface	77
HARD SANDSTONE	77	100

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6"	NEW BLACK STEEL A-53 18.97 P.E. DR.	Surface	87	

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
CEMENT	Surface	87'

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on **7-9** 19**83**

11. MISCELLANEOUS DATA

Yield Test: **2** Hrs. at **8** GPM Well is terminated **10** inches above below final grade

Depth from surface to normal water level **50** Ft. Well disinfected upon completion Yes No

Depth of water level when pumping **52** Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to **MADISON** laboratory on **7-18** 19**83**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **Kenneth Corpian** Registered Well Driller

Business Name and Complete Mailing Address **KENNETH CORPIAN & SONS
 RT 2 BOX 4 BOSCOBEL, WI 53805**