

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

MAR 17 1986

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <u>Freeman</u> <input type="checkbox"/> City		Name <u>Freeman</u>	
2. LOCATION 1/4 Section or Gov't. Lot <u>SW of NE 22 11N 7W</u> OR - Grid or Street No. Street or Road Name		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Dan Kumbin (Kumlin?)</u>		ADDRESS	
AND - If available subdivision name, lot & block No.		POST OFFICE <u>De Sota WI</u>		ZIP CODE <u>54625</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>50'</u>		Building		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I. Other		C.I. Other	
		C.I. Other		C.I. Sewer Other Sewer	
		C.I. Other		C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm		C.I. Other		Sewage Sump	
				Clearwater Sump	
				Septic Tank	
				Holding Tank	
				Sewage Absorption Unit	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench <u>80'</u>	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Subsurface Pump	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
				Earthen Manure Basin	
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Manure Storage Basin	
				Concrete Floor Only	
				Concrete Floor and Partial Concrete Walls	
				Other (Describe)	
5. Well is intended to supply water for: <u>home</u>		9. FORMATIONS			
		Kind		From (ft.)	To (ft.)
		<u>sand</u>		<u>Surface</u>	<u>80</u>
		<u>sand rock</u>		<u>80</u>	<u>100</u>
6. DRILLHOLE		Dia. (in.)		From (ft.)	To (ft.)
		<u>10</u>		<u>Surface</u>	<u>100</u>
		<u>6</u>		<u>90</u>	<u>90</u>
7. CASING, LINER, CURBING AND SCREEN		Material, Weight, Specification		From (ft.)	To (ft.)
		Dia. (in.) Mfg. & Method of Assembly			
		<u>6 new black PE 18.97</u>		<u>Surface</u>	<u>90</u>
		<u>PSI 1200</u>			
		<u>A-120</u>			
		<u>VSP adaptor</u>			
		<u>Reducer</u>			
8. GROUT OR OTHER SEALING MATERIAL		Kind		From (ft.)	To (ft.)
		<u>cement</u>		<u>8</u>	<u>90</u>
				<u>Surface</u>	
11. MISCELLANEOUS DATA		Yield Test: <u>3</u> Hrs. at <u>8</u> GPM		Well construction completed on <u>10-11 1985</u>	
		Depth from surface to normal water level <u>60</u> Ft.		Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
		Depth of water level when pumping <u>58</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
		Water sample sent to <u>Madison</u> laboratory on <u>11-18 1985</u>		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.		Signature			
		Business Name and Complete Mailing Address			
		<u>Donald Kirschbaum</u> Registered Well Driller		<u>Dons Well Drilling</u> <u>Rt 4 Roseabel WI 53805</u>	

231