

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

NOV 01 1987

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <u>Freeman</u>								
2. LOCATION ¼ Section or Gov't. Lot <u>NE ¼ NE ¼ 22</u> Section <u>11N</u> Township <u>7W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Larry Holt</u>			ADDRESS <u>R.R. 1</u>								
OR - Grid or Street No. Street or Road Name		AND - If available subdivision name, lot & block No.			POST OFFICE <u>DeSoto WI.</u> ZIP CODE <u>54624</u>								
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>35'</u>		Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I. Other		C.I. Other		C.I. Other		C.I. Other		C.I. Other		C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank	
San. Storm		C.I. Other		Sewer Clearwater Dr.		Sewage Sump Clearwater Sump		C.I. Other				Sewage Absorption Unit	
												Seepage Pit Seepage Bed Seepage Trench	
Privy Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard		Silo With Pit	
		Well Pump Tank		Nonconforming Existing								Glass Lined Storage Facility	
												Silo w/o Pit	
												Earthen Silage Storage Trench Or Pit	
												Earthen Manure Basin	
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin		Other (Describe)	
										Concrete Floor Only		Concrete Floor and Partial Concrete Walls	
												<u>City Sewer System</u>	
5. Well is intended to supply water for: <u>Private</u>				9. FORMATIONS									
				Kind		From (ft.)		To (ft.)					
6. DRILLHOLE				<u>Sand & gravel</u>		<u>0</u>		<u>70</u>					
Dia. (in.)		From (ft.)		To (ft.)		Surface							
<u>10</u>		<u>0</u>		<u>76</u>									
<u>6</u>		<u>76</u>		<u>95</u>		<u>Shale & sandrock</u>		<u>70</u>					
7. CASING, LINER, CURBING AND SCREEN													
Dia. (in.)		Material, Weight, Specification		From (ft.)		To (ft.)							
<u>6</u>		<u>New Black steel</u>		<u>Surface</u>		<u>76</u>							
		<u>Plain End</u>											
		<u>CAC ASTM</u>											
		<u>A-120 18-97</u>											
		<u>6x21</u>											
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED									
Kind		From (ft.)		To (ft.)		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water							
<u>Pitless Adaption</u>		<u>Surface</u>		<u>7</u>									
<u>Cement</u>		<u>7</u>		<u>76</u>									
				Well construction completed on <u>10-11 1987</u>									
11. MISCELLANEOUS DATA				Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below									
Yield Test: <u>2</u> Hrs. at <u>8</u> GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No									
Depth from surface to normal water level <u>48</u> Ft.		Water sample sent to <u>MADISON</u> laboratory on <u>10-14 1987</u>											
Depth of water level when pumping <u>63</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No													

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Michael D. Blumhorn Registered Well Driller Business Name and Complete Mailing Address CORPIAN Well Drilling R.R. 2 Boscobel WI. 53803