

NOTE:

- White Copy - Division's Copy
- Green Copy - Driller's Copy
- Yellow Copy - Owner's Copy

JAN 14 1982

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Freeman

2. LOCATION SW of SW Section 24 Township 7N Range 7W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Dale Hanson

OR - Grid or Street No. Street or Road Name TIIN ADDRESS Desota Wi 54624

AND - If available subdivision name, lot & block No. POST OFFICE ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) 20'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank	
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other					Seepage Pit	Seepage Bed	Seepage Trench	

Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard		Silo With Pit		Glass Lined Storage Facility		Silo w/o Pit		Earthen Silage Storage Trench Or Pit		Earthen Manure Basin	
				Well	Pump																		

Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin		Other (Describe)	
										Concrete Floor Only	Concrete Floor and Partial Concrete Walls		

5. Well is intended to supply water for Country Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	362	6	362	500

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	20
lime Rock	20	280
Sand Rock	280	320
Shale	320	500

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	new black steel PE 18.97 A-53 Valley Steel Pitless adaptor	Surface	362

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
Cement	8	362

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on 1-4 1982

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM

Depth from surface to normal water level 440 Ft.

Depth of water level when pumping 450 Ft. Stabilized  Yes  No

Well is terminated 12 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison Wi laboratory on 1-13 1982

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller

Business Name and Complete Mailing Address RT4 Box 75 Roscobel W. 53805

234