

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <u>Freeman</u>	
2. LOCATION 1/4 Section or Gov't. Lot <u>NE of NE ✓</u> OR - Grid or Street No. _____ Street or Road Name _____ AND - If available subdivision name, lot & block No. _____		Section <u>36</u>	Township <u>11N</u>	Range <u>7W</u>	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>John J Schmitz</u>	
		ADDRESS <u>2742 E Plankinton Ave</u>			POST OFFICE <u>Cudahy Wis</u> ZIP CODE <u>53110</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>20'</u>		Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain
		C.I.	Other	C.I.	Other	C.I.
		San. Storm	Other	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump
		C.I.	Other	Sewer	Sewage Sump	Clearwater Sump
		Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank	
		not in		Sewage Pit		
				Sewage Bed		
				Sewage Trench		
Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumphouse	Barn Gutter	Animal Barn Pen	Animal Yard
		Well	Nonconforming Existing			
		Pump				
		Tank				
Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only	
					Concrete Floor and Partial Concrete Walls	
5. Well is intended to supply water for: <u>trailer home</u>				9. FORMATIONS		
6. DRILLHOLE				Kind	From (ft.)	To (ft.)
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)			
<u>10</u>	<u>Surface</u>	<u>72</u>	<u>6</u>	<u>clay</u>	<u>Surface</u>	<u>10</u>
				<u>sand &amp; loose rock</u>	<u>10</u>	<u>56</u>
				<u>shale</u>	<u>56</u>	<u>100</u>
7. CASING, LINER, CURBING AND SCREEN						
Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)			
<u>6</u>	<u>new black steel PE 18.97</u>	<u>Surface</u>	<u>72</u>			
	<u>PSI-1200</u>					
	<u>A-120</u>					
	<u>USP</u>					
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED		
Kind		From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<u>clay</u>		<u>Surface</u>	<u>8</u>	<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<u>cement</u>		<u>8</u>	<u>72</u>	<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water
				Well construction completed on <u>8-12</u> 19 <u>86</u>		
11. MISCELLANEOUS DATA				Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Yield Test: <u>3</u> Hrs. at <u>8</u> GPM		Depth from surface to normal water level <u>80</u> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>82</u> Ft.		Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>8-12</u> 19 <u>86</u>						

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller Business Name and Complete Mailing Address 16189 Dutch Hill Rd  
Don Well Drilling Boscobel Wis 53605