

**RECEIVED**

SEP 18 1987

NOTE:

- White Copy - Division's Copy
- Green Copy - Driller's Copy
- Yellow Copy - Owner's Copy

RECEIVED-DNR

SEP 21 1987

WELL CONSTRUCTOR'S REPORT  
Form 3300-15 Rev. 5-85

1. COUNTY Crawford CHECK (✓) ONE:  Cross Area  Village  City Wausau

2. LOCATION SE of NE 1/4 Section of Gov't. Lot Section 15 Township 7N Range 5W  
OR - Grid or Street No. Street or Road Name ADDRESS 2935 W Silver Spring Dr

AND - If available subdivision name, lot & block No. POST OFFICE Milwaukee ZIP CODE WI 53209

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 12' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Clearwater Sump

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: country home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	110	6	110	380	Clay + rock	Surface	8
						lime rock	8	240
						Shale	240	380

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	new black steel PE 18.97	Surface	110
	PSI-1200		
	A-120		
	USP pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	110

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on: 1-16 19 87

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches  above final grade  below

Depth from surface to normal water level 340 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 342 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 6-15 19 87

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kiser Registered Well Driller Business Name and Complete Mailing Address Done Well Drilling, Baselet WI 53805