

State of Wisconsin
 Department of Natural Resources
 Box 450
 Madison, Wisconsin 53701

Copies as T6N R6W Sec. UNLOC
 + UNLOC. for County
 NOTE: FEB 18 1977

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
 Form 3300-15
 Rev. 10-75

1. COUNTY <i>Crawford</i>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <i>Bridgeport</i>								
2. LOCATION OR - Grid or Street No. <i>NW 6</i> Street Name <i>T6N R6W??</i>		Township <i>T6N</i> Range <i>R6W</i>		3. NAME <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <i>Ralph Schneyer</i>									
AND - If available subdivision name, lot & block No.				POST OFFICE <i>Bridgeport</i>									
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I. Other		C.I. Other		C.I. Other		C.I. Sewer Other Sewer		C.I. Other		C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank	
San. Storm		C.I. Other		Sewer Clearwater Dr.		Sewage Sump Clearwater Sump		C.I. Other		Septic Tank		Holding Tank	
Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard	
				Well Pump Tank		Nonconforming Existing				Silo With Pit		Glass Lined Storage Facility	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)			
5. Well is intended to supply water for: <i>Line stock</i>				9. FORMATIONS				Kind		From (ft.)		To (ft.)	
6. DRILLHOLE								<i>Clay</i>		Surface		<i>22</i>	
Dia. (in.) From (ft.) To (ft.)				Dia. (in.) From (ft.) To (ft.)				<i>Sandstone</i>		<i>22</i>		<i>64</i>	
<i>10</i> Surface <i>27</i>													
<i>6</i> <i>27</i> <i>64</i>													
7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly				From (ft.) To (ft.)									
<i>6" New steel to c. 19.45 surface</i>													
<i>A-53 galvanized</i>				<i>27</i>									
8. GROUT OR OTHER SEALING MATERIAL				Kind From (ft.) To (ft.)				10. TYPE OF DRILLING MACHINE USED					
<i>Cement</i>				Surface <i>27</i>				<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary					
11. MISCELLANEOUS DATA				Yield Test: <i>2</i> Hrs. at <i>25</i> GPM				Well construction completed on <i>8-2</i> 1976					
Depth from surface to normal water level <i>30</i> Ft.				Depth of water level when pumping <i>30</i> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Well is terminated <i>8</i> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below					
Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Water sample sent to <i>Madison</i> laboratory on <i>Feb 8</i> 1977					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.				Signature <i>R57</i> <i>Ralph Faherty</i> Registered Well Driller				Complete Mail Address FABERTY DRILLING CO., INC. 1133 Broadway EAU CLAIRE, WISCONSIN 54601					