

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Prairie du Chien

2. LOCATION (Number and Street of 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
NW Part of Sect. 18 T7N R6-W Lot 12 ???

3. OWNER AT TIME OF DRILLING Mr. Jack White (Cliffwood Edition)

4. OWNER'S COMPLETE MAIL ADDRESS R 70 Prairie du Chien, Wis. 53821

5. Distance in feet from well to nearest:

(Record answer in appropriate block)	BUILDING		SANITARY SEWER		FLOOR DRAIN		FOUNDATION DRAIN		WASTE WATER DRAIN	
	C. I.	TILE	C. I.	TILE	C. I.	TILE	SEWER CONNECTED	INDEPENDENT	C. I.	TILE
	25'	30'			30'					

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	80'			90'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for:

Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	15	6	15	100	loose stone & black dirt	Surface	15
						loose sand	15	53
						sand stone	53	100

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	Standard new black plain end 19.18	Surface	63

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	15
loose sand	15	53

11. MISCELLANEOUS DATA			
Yield test:	8 Hrs. at	15 GPM	Well construction completed on 4 - 9 - 1968
Depth from surface to normal water level	55 ft.	Well is terminated 8 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade	
Depth to water level when pumping	58 ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to <u>Madison, Wis.</u>		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	laboratory on: 6 - 4 - 1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE	COMPLETE MAIL ADDRESS
<u>Kenneth Coplan</u> Registered Well Driller	<u>53805 R 3 Box 84 Boscobel, Wis.</u>

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
259				