

NOV 3 1983

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Wauzeka

2. LOCATION SE of NE 1/4 Section of Gov't. Lot 15 Section 7N Township 5W Range

3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Vincent J. Gucciardo

OR - Grid or Street No. Street or Road Name ADDRESS 4911 Chesterfield Ave

AND - If available subdivision name, lot & block No. POST OFFICE Rockford, Ill ZIP CODE 61109

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>20'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer	Sewage Sump	Clearwater Sump			Seepage Pit Seepage Bed Seepage Trench	
		Clearwater Dr.					<u>72'</u>	<u>82'</u>

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>356</u>	<u>6</u>	<u>356</u>	<u>380</u>	<u>clay</u>	<u>Surface</u>	<u>0</u>
						<u>lime rock</u>	<u>4</u>	<u>210</u>
						<u>sand rock</u>	<u>210</u>	<u>320</u>
						<u>shale</u>	<u>320</u>	<u>380</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel</u>	<u>PS 1 1200</u>	<u>Surface</u>	<u>356</u>
	<u>A-120</u>	<u>Valley steel</u>		
	<u>Pittsboro</u>	<u>1897</u>		
	<u>PE</u>			

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>cement</u>	<u>8</u>	<u>356</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 10-14 1983

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 7 GPM Well is terminated 12 inches  above final grade  below

Depth from surface to normal water level 310 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 315 Ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 10-24 1983

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Knudsen Registered Well Driller Business Name and Complete Mailing Address Box 75  
Done Well Drilling Box 75