

JAN 31 1973

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

**NOTE**  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Praire Du Chien

2. LOCATION - 1/4 Section Section 7-N Township 7-N Range 6-W 3. OWNER AT TIME OF DRILLING Ray Poskozim

OR - Grid or street no. Farm Lot 20 Street name Cliffwood Drive ADDRESS R.R.1 Cliffwood Dr.

AND - If available subdivision name, lot & block no. Ahrens' Coulee Lot 5 Block 1 POST OFFICE Praire Du Chien

4. Distance in feet from well to nearest: BUILDING 38 SANITARY SEWER C.I. 45 TILE FLOOR DRAIN C.I. 50 TILE FOUNDATION DRAIN SEWER CONNECTED 38 INDEPENDENT WASTE WATER DRAIN C.I. None TILE

CLEAR WATER DRAIN C.I. None TILE SEPTIC TANK 90 PRIVY None SEEPAGE PIT 105 ABSORPTION FIELD 110 BARN None SILO ABANDONED WELL None SINK HOLE None

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) None

5. Well is intended to supply water for: House

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	42	6	42	106	Black Dirt	Surface	5	
						Yellow Clay	5	35	

7. CASING, LINER, CURBING, AND SCREEN				9. FORMATIONS			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
6	New Steel P. E.	Surface	106	Brown Sandy Drift	35	65	
	18.97/ft.			Gray Mud & Drift	65	85	
				Orange Sand & Drift	85	101	
				Jordan Sandstone	101	126	

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)  
Puddled Clay Surface 42  
Drive Shoe 42 106

10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water  
Well construction completed on 11-2 19 72

11. MISCELLANEOUS DATA  
Yield test: 4 Hrs. at 12 GPM Well is terminated 14 inches  above  below final grade  
Depth from surface to normal water level 38 ft. Well disinfected upon completion  Yes  No  
Depth to water level when pumping 46 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to State Lab. of Hygiene at Madison laboratory on: 1-30 1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side. System operable 1-24-73

SIGNATURE Duane Lubbers W.D. 410 Registered Well Driller COMPLETE MAIL ADDRESS Duane Lubbers Farmersburg, Iowa 52047

Please do not write in space below  
COLIFORM TEST RESULT 262 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS  
REV. 3-71