

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

JAN 31 1973

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Praire Du Chien

2. LOCATION - 1/4 Section 7-N Township 6-W Range 6-W 3. OWNER AT TIME OF DRILLING Bruce Dillman

OR - Grid or street no. Farm Lot 20 Street name Coulee Court ADDRESS 615 N. Minn. St.

AND - If available subdivision name, lot & block no. Ahrens' Coulee Lot 3 Block 2 POST OFFICE Praire Du Chien

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER C.I.	TILE	FLOOR DRAIN C.I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C.I.	TILE
12	40		None		12		None	

CLEAR WATER DRAIN C.I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
None		110	None	140	None	None		None	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) None

5. Well is intended to supply water for: New House

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	40	6	40	126	Yellow Clay	Surface	40
						Brown Sandy Drift	40	60

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	New Steel P. E.	Surface	102
	18.97#/ft.		

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
Puddled Clay	Surface	40	<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
Drive Shoe	40	102	Well construction completed on <u>11-27 1972</u>		

11. MISCELLANEOUS DATA			
Yield test:	1	Hrs. at	25 GPM
Depth from surface to normal water level	50	ft.	
Depth to water level when pumping	65	ft.	
Well is terminated	12	inches	<input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		

Water sample sent to System operational in March laboratory on: 19

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side. Yield test- Bailing with machine

SIGNATURE Duane Lubbers W.D. 410 Registered Well Driller COMPLETE MAIL ADDRESS Duane Lubbers Farmersburg, Iowa 52047

Please do not write in space below

COLIFORM TEST RESULT <u>263</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
---------------------------------	---------------	---------------	-----------	---------