

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

**NOTE**  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford		CHECK ONE <input type="checkbox"/> Town <input type="checkbox"/> Village <input checked="" type="checkbox"/> City		NAME Praire Du Chien	
2. LOCATION - 1/4 Section Farm Lot 20		Section 18A		Township 7-N	
OR - Grid or street no. Farm Lot 20		Street name Cliffwood Dr.		3. OWNER AT TIME OF DRILLING Charles Lange	
AND - If available subdivision name, lot & block no. Ahrens Coulee Lot 9 Blk. 2				ADDRESS 216 N. Michigan St.	
				POST OFFICE Praire Du Chien, Wisc.	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT
		48			Not Yet Installed
CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN SILO
					None
				ABANDONED WELL SINK HOLE	
				None	
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) None					

5. Well is intended to supply water for:  
House

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	35	6	35	120	Black Dirt	Surface	5
						Yellow Clay	5	35
7. CASING, LINER, CURBING, AND SCREEN						Gray Mud	35	70
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)		Orange Sand & Drift	70	75
6	New Steel P. E.		Surface	103		Brn. Sandy Drift	75	95
	18.97# per Ft.					Orange Sand & Drift	95	100
						Jordan Sandstone	100	120

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
Puddled Clay	Surface	35	<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
Drive Shoe	35	103	Well construction completed on 7-21 19 72		

11. MISCELLANEOUS DATA			Well is terminated 18 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Yield test: 5	Hrs. at 11	GPM	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth from surface to normal water level 35	ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping 40	ft.		
Water sample sent to State Lab. of Hygiene; Madison, Wisc.			laboratory on: 7-25 1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Duane Lubbers Registered Well Driller	COMPLETE MAIL ADDRESS Duane Lubbers Farmersburg, Iowa 52047
---	---

Please do not write in space below

COLIFORM TEST RESULT 264	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-----------------------------	---------------	---------------	-----------	---------