


WELL CONSTRUCTOR'S REPORT
FORM 3300-15

JAN 23 1973

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford		CHECK ONE			NAME	
		<input checked="" type="checkbox"/> Town	<input type="checkbox"/> Village	<input type="checkbox"/> City	Bridgeport	
2. LOCATION - 1/4 Section Section Township Range		6-N		6-W		3. OWNER AT TIME OF DRILLING Elaine Kramer
OR - Grid or street no. Farm Lot 20		Street name 		ADDRESS Kramers Country Court R. R. 2		
AND - If available subdivision name, lot & block no. No block or lot numbers		POST OFFICE Prairie Du Chien				
4. Distance in feet from well to nearest: <small>(Record answer in appropriate block)</small>		BUILDING C. I.	SANITARY SEWER C. I.	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT	WASTE WATER DRAIN C. I.
		130	30	None	None	None
CLEAR WATER DRAIN C. I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO
None	175	None	175	175	130	None
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)		None				

5. Well is intended to supply water for: Trailer Court


6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
6	Surface	154				Fine Sand	Surface	62
						Black Mud	62	86
7. CASING, LINER, CURBING, AND SCREEN								
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)				
6	New Steel P. E. 18.97#/ft.		Surface	96		Coarse sand & Gravel	86	92
						Gray Limestone	92	154

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
Drive Shoe	Surface	96	<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
			Well construction completed on 11-15 1972		

11. MISCELLANEOUS DATA			Well is terminated 20 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Yield test:	5	Hrs. at 30	GPM	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth from surface to normal water level	30	ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth to water level when pumping	120	ft.			

Water sample sent to State Lab. of Hygiene at Madison laboratory on: 1-24 1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side. System operational 1-19-73

SIGNATURE 	W.D. 410 Registered Well Driller	COMPLETE MAIL ADDRESS Duane Lubbers Farmersburg, Iowa 52047
---	-------------------------------------	---

Please do not write in space below

COLIFORM TEST RESULT 267 REV. 3-71	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
--	---------------	---------------	-----------	---------