

1. COUNTY Crawford CHECK ONE Town Village City NAME Prairie du Chien
 2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
Farm 20 (S.E. Corner of Lot 11) Cliffwood Division 7N 6W

3. OWNER AT TIME OF DRILLING Les Resiwedt ~~Schwartz~~

4. OWNER'S COMPLETE MAIL ADDRESS R 7 D Prairie du Chien, Wis. 53821

5. Distance in feet from well to nearest:
 (Record answer in appropriate block)

| | | | | | | | |
|---------------|---------------------|------------------|------|----------------------------------|-------------|------------------------|------|
| BUILDING C.I. | SANITARY SEWER TILE | FLOOR DRAIN C.I. | TILE | FOUNDATION DRAIN SEWER CONNECTED | INDEPENDENT | WASTE WATER DRAIN C.I. | TILE |
| 15' | 25' | | | | | 25' | |

| | | | | | | | | | |
|------------------------|------|-------------|-------|--------------|------------------|------|------|----------------|-----------|
| CLEAR WATER DRAIN C.I. | TILE | SEPTIC TANK | PRIVY | SERPENT PITS | ABSORPTION FIELD | BARN | SILO | ABANDONED WELL | SINK HOLE |
| | | 80' | 0 | 0 | 90' | 0 | 0 | 0 | 0 |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) 0

6. Well is intended to supply water for: Home

| 7. DRILLHOLE | | | | | | 10. FORMATIONS | | |
|--------------|------------|----------|------------|------------|----------|-------------------|------------|----------|
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
| 10 | Surface | 65 | 6 | 65 | 100 | Clay | Surface | 15 |
| | | | | | | loose rock & Clay | 15 | 30 |

| 8. CASING, LINER, CURBING, AND SCREEN | | | | 10. FORMATIONS | | |
|---------------------------------------|------------------------|------------|----------|----------------------------|------------|----------|
| Dia. (in.) | Kind and Weight | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
| 6 | plain end, black 19.18 | Surface | 65 | limestone | 30 | 65 |
| | | | | sandstone | 65 | 95 |
| | | | | water-bearing loose gravel | 95 | 100 |

| 9. GROUT OR OTHER SEALING MATERIAL | | |
|------------------------------------|------------|----------|
| Kind | From (ft.) | To (ft.) |
| Clay | Surface | 30 |
| Cement | 30 | 65 |

11. MISCELLANEOUS DATA
 Yield test: 6 Hrs. at 18 GPM
 Well is terminated 12 inches above below final grade
 Well disinfected upon completion Yes No
 Well sealed watertight upon completion Yes No
 Depth from surface to normal water level 60 ft.
 Depth to water level when pumping 70 ft.

Water sample sent to Madison laboratory on: 6-27-1967

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R 3 Box 36, Boscobel, Wis. 53805

Please do not write in space below

| COLIFORM TEST RESULT | GAS - 24 HRS. | GAS - 48 HRS. | CONFIRMED | REMARKS |
|----------------------|---------------|---------------|-----------|---------|
| 268 | | | | |