

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

CR-182-G


1. COUNTY Crawford		CHECK ONE <input type="checkbox"/> Town <input type="checkbox"/> Village <input checked="" type="checkbox"/> City		NAME Prairie du Chien, Wisconsin	
2. LOCATION - 1/4 Section NE 1/4 31		Section 7N		Range 3W R6W	
OR - Grid or street no. -		Street name Wells and 18th Streets		3. OWNER AT TIME OF DRILLING City of Prairie du Chien, Wisconsin	
AND - If available subdivision name, lot & block no. C. of Southline E 1/2, FARM LOT 35				ADDRESS P. O. Box 324, Prairie du Chien, Wisconsin	
				POST OFFICE Prairie du Chien, Wisconsin 53821	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING 100'	SANITARY SEWER C. I. 75'	FLOOR DRAIN C. I. -	FOUNDATION DRAIN SEWER CONNECTED/INDEPENDENT -
CLEAR WATER DRAIN C. I. 75'	SEPTIC TANK TILE -	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN
	250'				SILO
					ABANDONED WELL
					SINK HOLE
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) None					

5. Well is intended to supply water for:
Municipal Water Supply

6. DRILLHOLE				9. FORMATIONS					
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
36	Surface	61				Sand and Gravel	Surface	101	
30	61	138' 7"				Sand, Gravel and Lime	101'	109	
7. CASING, LINER, CURBING, AND SCREEN				Sand and Gravel				109'	138'
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)					
36"	Blk. St1. (1/2" Wall) 189#/ft.		Surface	61' 3"					
30"	" " (1/2" Wall) 157#/ft.		0	97'					
18"	" " (3/8" Wall) 70.6#/ft.		0	98' 4"					
18"	Stainless-Steel Screen		98' 4"	138' 7"					
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED					
Kind		From (ft.)	To (ft.)		<input checked="" type="checkbox"/> Cable Tool <input type="checkbox"/> Direct Rotary <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Rotary - air w/drilling mud <input type="checkbox"/> Rotary - hammer with drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water				
Neat Cement		Surface	61'		Well construction completed on August 31, 1979				
11. MISCELLANEOUS DATA				Well is terminated 24 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade					
Yield test:	24	Hrs. at	1600-	GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth from surface to normal water level		31' 1"		ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			

Water sample sent to **Madison, Wisconsin** laboratory on: **Aug. 9, 1979**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE 	COMPLETE MAIL ADDRESS Keys Well Drilling Company 413 N. Lexington Parkway, St. Paul, Minn. 55104
George H. Keys, President	Registered Well Driller

Please do not write in space below

COLIFORM TEST RESULT 276	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------